



Raymond RC Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011590	3/26/2020	3/26/2021	2	Cooler	In hallway adjacent to mens' restroom	High	Left	WF-03262020-011590	3/9/2021	FT-FY21-022021-011590-A	<1	FT-FY21-022021-011590-B	<1
WS- 011591	3/26/2020	3/26/2021	2	Cooler	In hallway adjacent to mens' restroom	Low	Right	WF-03262020-011591	3/9/2021	FT-FY21-022021-011591-A	<1	FT-FY21-022021-011591-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011586	1/12/2021	1/12/2022	2	Food Prep Sink	In kitchen 209	WF-01122021-011586	3/9/2021	FT-FY21-022021-011586-A	<1	FT-FY21-022021-011586-B	<1